



DECLARATION OF CONFORMITY

GENERATING SET

MODEL	P110E	
SERIAL NUMBER	E1623C/003	
YEAR OF MANUFACTURE	1999	
RATED POWER - STANDBY	110	kVA
	88	kW
	0.8	COS Ψ
RATED VOLTAGE	380 / 220	V
PHASE	3	
RATED FREQUENCY	50	Hz
RATED CURRENT	167.1	A
RATED R.P.M	1500	
MAXIMUM ALTITUDE *	152.5	m
MAXIMUM AMBIENT TEMPERATURE *	30	°C
MASS	1940	kg
ALTERNATOR CONNECTION	S'STAR	
RATING ISO 8528-3	PR 500H TL0.875	
ALTERNATOR ENCLOSURE	IP22	
INSULATION CLASS	H	
EXCITATION VOLTAGE	38	V
EXCITATION CURRENT	1.9	A
A.V.R	SX460	

This generating set conforms to the following
EC directives

Cumple las siguientes directrices de la CE

89/336/EEC, 92/31/EEC, 93/68/EEC
89/392/EEC, 91/368/EEC, 93/44/EEC
73/23/EEC, 93/68/EEC
84/536/EEC

DECLARACION DE CONFORMIDAD

GRUPO ELECTROGENO

MODELO	
NUMERO DE SERIE	
ANO DE CONSTRUCCION	
POTENCIA EN KVA	
TENSION	
FASE	
FRECUENCIA	
CORRIENTE	
RPM	
ALTITUD MAXIMA	
MAXIMA TEMPERATURA AMBIENTE	
PESO	
CONEXION DEL ALTERNADOR	
POTENCIA ISO 8528-3	
CUERPO DEL ALTERNADOR	
CLASE DE AISLAMIENTO	
VOLTAJE DE EXCITACION	
CORRIENTE DE EXCITACION	
REGULADOR AUTOMATICO DE VOLTAGE	

P. Doyle
Quality Assurance Manager

F.G WILSON (ENGINEERING) LTD

OLD GLENARM ROAD, LARNE,
Co. ANTRIM, BT40 1EJ,
NORTHERN IRELAND, UNITED KINGDOM.

TELEPHONE: (44) 1574 261000
FACSIMILE: (44) 1574 261111
TELEX: 747448 GENSET G

